

LOCATION 1019 + 1021 E. AIRLINECITY GASTONIABETWEEN WARRENSTREET & DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLAS	110'		6-12-97	
MAIN TO PROP. LINE	11	11	5'			
PROP. LINE TO BLDG.	11	11	105'			

ENTERS: 1019 E AIRLINEBRANCHED INTO: 1021 E. AIRLINETAP SIZE: 3/4"PRESSURE 60

PSI

INCHES W.C.

LOCATION N. SIDE 1019PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BT.MAIN-SIZE 2"

C.I. _____

BARE STEEL _____


COATED STEEL _____

PLASTIC ☒YEAR INSTALLED 97DEPTH: 3 FT. 6 IN.LOCATION W. SIDE 1019"A" P/S READING N/A

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY