

LOCATION 1126 W. Airline CITY Gastonia  
BETWEEN Five Stone St STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>Bonded Insulated</u>			
MAIN TO PROP. LINE			<u>Tee</u>	<u>5-23-00</u>		
PROP. LINE TO BLDG.				<u>E pump</u>		

ENTERS: 1126 BRANCHED INTO: 0

TAP SIZE: PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ \_\_\_\_\_ PSI FOR \_\_\_\_\_ HRS. BY \_\_\_\_\_

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1968

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING 1.072 TOTAL ANODES 1# 0 17# 1 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.200</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY