

LOCATION 321 W. Allison Ave. CITY East.

BETWEEN Allison St. STREET & Beatrice Eastner STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>41'</u>			<u>9-5-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>22'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>19'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 132' from @ of

Allison Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY _____

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION W. of Grace St.

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY