

LOCATION 3021 Alton Dr CITY Castroville

BETWEEN Robinson Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RELOCATED RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>40'</u>			<u>7-10-02</u>
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS 3021 BRANCHED INTO 3025

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION W. of center of Alton Dr.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S. H.

MAIN-SIZE	C I	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED
<u>3/4"</u>			<input checked="" type="checkbox"/>		

DEPTH 2 FT 0 IN LOCATION N. of center of Robinson Rd.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	