

LOCATION 2743 Ambercrest DR. CITY GASTONIA

BETWEEN Elkhorn Ln. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>58"</u>	<u>P</u>	<u>55'</u>	<u>11-25-02</u>		
MAIN TO PROP LINE	<u>58"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG.	<u>58"</u>	<u>P</u>	<u>50</u>			

ENTERS 2743 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 60' E. of center of Elkhorn Ln


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SM

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 20' S. of center of Ambercrest DR

"A" P/S READING P TOTAL ANODES 1# 17# LR # 349295

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	