

LOCATION 2706 Ambercrest DR. CITY CASTON

BETWEEN Antlers CT. STREET & 1 STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>70'</u>	<u>10-21-82</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>60'</u>			

ENTERS 2706 BRANCHED INTO 2772

TAP SIZE 3/4" PRESSURE 60 PSI 60 INCHES W C LOCATION 212' SW. of center of Antlers CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2002

DEPTH 3 FT 0 IN LOCATION 32' W. of center of Ambercrest DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 312052

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	