

LOCATION 1216 Anderson CT CITY Gastonia
 BETWEEN 12th STREET & Betty STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	63	2-25-99		
MAIN TO PROP. LINE	1	1	5			
PROP. LINE TO BLDG.	1	1	58			

ENTERS: 1216 BRANCHED INTO: _____

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 16' E. of C of


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP Anderson

MAIN SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1959

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING 1.00 TOTAL ANODES 1# 17 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	