

LOCATION

117 &amp; 119 ANN ST.

CITY

Gast.

BETWEEN

CRAIG

STREET

&amp;

WARREN

STREET

	SIZE	TYPE	117 LENGTH	119	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	96'	36'		6-10	97
MAIN TO PROP. LINE	"	"	5'	0			
PROP. LINE TO BLDG.	"	"	91'	36'			

ENTERS:

117

BRANCHED INTO:

119

TAP SIZE:

3/4"

PRESSURE

60

PSI

INCHES W.C.

LOCATION

W. side of 117  
" " " 119

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

BT

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

97

DEPTH:

4 FT.

IN.

LOCATION

W. side of Ann St.

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

S

P

P/S Pipeline Lead - White  
Existing Main

E

ENG. DEPT. USE ONLY