

LOCATION 1850 Abbottsford Cr CITY GASTON

BETWEEN NORSEMAN CR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>115'</u>	<u>9.30-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>47'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>68'</u>			

ENTERS 1850 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 185' W. of center of Norseman Cr


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S. G.

MAIN-SIZE 2" C I' BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 22' N. of center of Abbottsford Cr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 281796

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	