

LOCATION 123 ANN ST. CITY GASTONIA

BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>109'</u>		<u>6-10-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>104'</u>			

ENTERS: SAME BRANCHED INTO: _____

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION W. SIDE OF 123


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.T.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 97

DEPTH: 3 FT. IN. LOCATION W. SIDE OF ANN ST.

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY