

LOCATION 409 A Apple St CITY GASTONIA
 BETWEEN Cedar STREET & E/M STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>88'</u>	<u>3-12-99</u>	<u>3-12-99</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>8'</u>		<u>orig inst</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>80'</u>		<u>4-16-78</u>	

ENTERS: 409 A BRANCHED INTO 409 B
 TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 284' N of Cedar

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Parker

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN. LOCATION 12' W of Apple

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ I.R. # _____

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RISK</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

