

LOCATION 604 Apple CITY GASTONIA
 BETWEEN Hemlock STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	51'			
MAIN TO PROP. LINE	3/4	P	30'	11-18-99		
PROP. LINE TO BLDG	3/4	P	21'			

 ENTERS 604 BRANCHED INTO 0
 TAP SIZE 3/8 PRESSURE 60 PSI INCHES W.C. LOCATION
 PRESSURE TEST 100 PSI FOR 1/4 HRS BY EP
 MAIN SIZE 1 1/2 C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED
 DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1# - 17# - LR #

REMARKS:

Test Station		
Reading & Location	Lead	Volt
P/S Pipeline Lead Red New Service	S	Plastic
P/S Pipeline Lead White Existing Main	E	

