

LOCATION 714 Appleblossom Cir CITY Gastonia  
 BETWEEN Essex STREET & Dead End STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>122'</u>		<u>X</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>0'</u>			<u>6-17-94</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>122'</u>			

ENTERS: 714 BRANCHED INTO: 0  
 TAP SIZE: 1" Ser PRESSURE 20 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By SP  
 MAIN-SIZE 1" C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1956  
 DEPTH: 2 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING 18 TOTAL ANODES 1# 1 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
Could not find old bare main, came out ext 1" bare service in front yard.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R. Ser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY