

LOCATION 4901 APRIL DR CITY Gastonia  
BETWEEN PLAZA CT STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>107'</u>	<u>1-7-99</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>23'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>84'</u>			

ENTERS: 4901 BRANCHED INTO: -

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 13' w. of c of April Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1972

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.40 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY