

LOCATION 2644 Aberdeen Blvd.

CITY Gastonia

BETWEEN Cox Rd.

STREET & Scalybark Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$ "	P	121'	7-25-95		
MAIN TO PROP. LINE	$\frac{3}{4}$ "	P	10'	7-25-95		
PROP. LINE TO BLDG.	$\frac{3}{4}$ "	P	111'	7-25-95		

ENTERS: 2644 Aberdeen Blvd.

BRANCHED INTO:

TAP SIZE: $\frac{1}{2}$ " PRESSURE 60 P.S.I. INCHES W.C. LOCATION 918' east of center of Cox Rd.


PRESSURE TEST: @ 100 psi For $\frac{1}{4}$ Hrs. By R. Rutledge

MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. In. LOCATION 15' south of center of Aberdeen Blvd.

"A" P/S READING P. TOTAL ANODES 1* — 17* — L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P.
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY