

LOCATION 1816 Archwood Dr. CITY Constonia
BETWEEN Chestnut STREET & Mary Lee STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Ø</u>	<u>113'</u>			<u>8-6-94</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Ø</u>	<u>90'</u>		<u>113' of 3/4" BARE</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Ø</u>	<u>9.3'</u>			

ENTERS: 1800 BRANCHED INTO: 1816

TAP SIZE: 3/4 IN. PRESSURE 40 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 114 Hrs. By EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 2 Ft. 0 In. LOCATION _____

"A" P/S READING Ø TOTAL ANODES 1* 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Ø</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY