

LOCATION 1830 & 1822 Archwood Dr. CITY Castonia
 BETWEEN Mary Lee STREET & Linwood Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>33'</u>	<u>8-6-94</u>	<u>Tied over</u>	<u>165' of ext 3/4"</u>
MAIN TO PROP. LINE					<u>Clos to ext</u>	<u>2" plastic</u>
PROP. LINE TO BLDG.					<u>Main</u>	

ENTERS: 1830 BRANCHED INTO: 1822

TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 14 Hrs. By EP


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

Tracer wire tied off at Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u># 1830 - 1.2</u> <u># 1822 - 1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY