


LOCATION 1860 + 1861 ArKrayCITY GastoniaBETWEEN BondSTREET & ArKray

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>10</u>	<u>12-14-91</u>		
MAIN TO PROP. LINE			<u>used to tie over services</u>		<u>to 4' Plastic</u>	
PROP. LINE TO BLDG.						

ENTERS: 1860BRANCHED INTO: 1861TAP SIZE: 3/4 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 168 East of
Center of BondPRESSURE TEST: @ 100 psi For 1/4 Hrs. By K HayesMAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991DEPTH: 3 Ft. _____ In. LOCATION 13 North of center of ArKray"A" P/S READING 1.1 csw TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY