

LOCATION 2616-B Armstrong Circle CITY GASTONIA
BETWEEN S. New Hope Rd. STREET & Sheffield Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>80'</u>	<u>10-23-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>80'</u>			

ENTERS: 2616 BRANCHED INTO: 2616-B
TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 950' E of S. New Hope Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

^{Service} MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1967

DEPTH: 2 Ft. 0 In. LOCATION 123' W of C of Armstrong Circle

"A" P/S READING .04 TOTAL ANODES 1# 1 17# _____ L.R. # 533336

REMARKS: Split Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY