

LOCATION 2625 Armstrong Cir CITY Gastonia
BETWEEN A.C. New Hope STREET & Sheffield Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>140'</u>	<u>7-31-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>90'</u>			

ENTERS: 2625 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 20' N. of cap
Armstrong Cir


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GP - RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1987

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		