


LOCATION 122 ARMSTRONG ST CITY GASTONIA
BETWEEN DZARK ST STREET & AIRLINE AVE STREET
MAIN TO BLDG SIZE 3/4 TYPE P LENGTH 66' INSTALLED 11-22-00 RETIRED RENEWED
MAIN TO PROP LINE SIZE 3/4 TYPE P LENGTH 8' INSTALLED RETIRED RENEWED
PROP LINE TO BLDG SIZE 3/4 TYPE P LENGTH 58' INSTALLED RETIRED RENEWED
METERS 122 BRANCHED INTO 0
PIPE SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 50' W of C of HANCOCK ST
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY LR
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997
DEPTH 3 FT 0 IN LOCATION 14' W of C of AIRLINE AVE
A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # 106806
REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic Riser
P/S Pipeline Lead - White Existing Main	E	