

LOCATION 1624 + 1626 Armstrong Ford Rd CITY Gastonia
BETWEEN S. New Hope Rd STREET & Crest STREET

| | SIZE | TYPE | 1624 LENGTH | 1626 | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|-------------|------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4 | P | 137' | 143' | 2-7-96 | | |
| MAIN TO PROP. LINE | 3/4 | P | 47' | 87' | | | |
| PROP. LINE TO BLDG. | 3/4 | P | 90' | 56' | | | |

ENTERS: 1624 Armstrong Ford Rd BRANCHED INTO: 1626 Armstrong Ford Rd

TAP SIZE: 3/4 PRESSURE 60 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. E. Moore

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # 053989-053990

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY