

LOCATION 1640 Armstrong Ford Rd. CITY GASTONIA
BETWEEN Crest St. STREET & S. New Hope Rd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	136'	2-21-96		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	91'			

ENTERS: 1640 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 260' W. of center of Crest St.

PRESSURE TEST: @ 100 psi For 14 Hrs. By S. HUFFSTILL
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 1996
DEPTH: 3 Ft. 0 In. LOCATION 21' S. of center of Armstrong Ford Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 74120

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY