

LOCATION 1679 Armstrong Ford Rd CITY Gastonia
BETWEEN Crest STREET & St. New Hope Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>93'</u>	<u>2-6-86</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>83'</u>			

ENTERS: 1679 Armstrong Ford Rd BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Elmore

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # 053985

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY