

LOCATION 301 Armstrong Park Rd CITY Castroville
BETWEEN Ruby Lane STREET & Planter / Car Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>4-16-94</u>	<u>Tied over</u>	<u>54'0" EPT</u>
MAIN TO PROP. LINE					<u>3/4 Plastic</u>	<u>Service to EPT</u>
PROP. LINE TO BLDG.					<u>2" Plastic</u>	<u>MAIN</u>

ENTERS: 301 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* 17* _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY