

LOCATION 1066 ARMSTRONG PARK RD CITY GASTONIA  
BETWEEN PERRY ST. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>2"</u>	<u>P</u>	<u>286</u>	<u>12-18-01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>77</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>209</u>			

ENTERS \_\_\_\_\_ BRANCHED INTO \_\_\_\_\_  
TAP SIZE 1 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION N. side of 1066


PRESSURE TEST @ 100 PSI FOR 15 HRS BY GL

MAIN-SIZE 6" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1963

DEPTH 7 FT IN \_\_\_\_\_ LOCATION W. side of Armstrong Park Rd.

"A" P/S READING 1.3 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	