

LOCATION 2410 Armstrong Park Rd. CITY Gastonia  
BETWEEN Dunham STREET & Harper STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>cmw</u>		<u>TIED OVER</u> <u>4-16-94</u>		
MAIN TO PROP. LINE				<u>48' EXIST</u>		
PROP. LINE TO BLDG.				<u>3/4" cmw</u>		

ENTERS: 2410 BRANCHED INTO: (8-7-92)

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 12' W OF


Dunham  
PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 90

DEPTH: 3 Ft. 0 In. LOCATION 74' N OF Armstrong Park Dr

"A" P/S READING 1.7 TOTAL ANODES 1# 1 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>1.7 cmw</u> <u>RISEK</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY