

LOCATION 2516 Armstrong Park Dr CITY Gastonia
BETWEEN Ruby STREET & Thomas Trail STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>	<u>4-16-94</u>		
MAIN TO PROP. LINE			<u>Tied over</u>	<u>80' Existing</u>	<u>3/4 Plastic</u>	
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 218 North of Armstrong Park


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. _____ In. LOCATION 11 West of Thomas Trail

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: Tracer Wire Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY