

LOCATION 2623 ARMstrong pk Rd

CITY Gastonia

BETWEEN Ruby

STREET & Armstrong

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	77'	10-12-93		
MAIN TO PROP. LINE	3/4	P	7'			
PROP. LINE TO BLDG.	3/4	P	70			

ENTERS: 2623

BRANCHED INTO: 0

TAP SIZE: 3/8

PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION E Side of 2623

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE 12" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1990


DEPTH: 3 Ft. 6 In. LOCATION 23' S of C of Armstrong pk Rd.

"A" P/S READING 1.2

TOTAL ANODES 1# - 17# -

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY