

LOCATION 805 Adams CtCITY GastoniaBETWEEN W. 7th AveSTREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	<i>P</i>	34'			9-10-93
MAIN TO PROP. LINE	$\frac{3}{4}$	<i>P</i>	16'		30' of $\frac{3}{4}$ " cfw	
PROP. LINE TO BLDG.	$\frac{3}{4}$	<i>P</i>	18'			


ENTERS: 805 Adams CtBRANCHED INTO: —TAP SIZE: $\frac{1}{2}$ PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 190' S of W 7th AvePRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. E. MooreMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION 8' E of Adams Ct"A" P/S READING *P* TOTAL ANODES 1* — 17* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<i>P</i>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY