

LOCATION 406 ARTHUR AV. CITY GASTONIA
BETWEEN YORK STREET & CLYDE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>66</u>		<u>03/27/98</u>	
MAIN TO PROP. LINE	<u>1 1</u>	<u>1 1</u>	<u>35</u>			
PROP. LINE TO BLDG.	<u>1 1</u>	<u>1 1</u>	<u>31</u>			


ENTERS: 406 BRANCHED INTO: Ø
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 108'Eg YORK

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY NS
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1998

DEPTH: 4 FT. IN. LOCATION 17'Sg ARTHUR

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tied over 23' EXISTING 3/4" PLASTIC SERVICE



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>XR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY