

LOCATION 510 W. AIRLINE CITY CAS.
BETWEEN CHESTER STREET & MORRIS STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	43		3. 5. 96	
MAIN TO PROP. LINE	"	"	3'			
PROP. LINE TO BLDG.	"	"	40'			

ENTERS: 510 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION W. side of shop

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GK
MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96
DEPTH: 3 Ft. _____ In. LOCATION E side of N. Bryce

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY