

LOCATION 618 W. Airline Ave CITY GASTONIA

BETWEEN Cherry ST STREET & N. Pryor ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4'</u>	<u>P</u>	<u>3'</u>	<u>5-4-96</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 618 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 92' N. of center of

W. Airline Ave


PRESSURE TEST: @ 105 psi For 1 1/4 Hrs. By S. Huffstiller

MAIN-SIZE 2' C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 Ft. 0 In. LOCATION 16' W. of center of Cherry ST

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY