

LOCATION 804 W AIRLINE Ave

CITY GASTONIA

BETWEEN Highland ST

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	38'	3/3/95		
MAIN TO PROP. LINE	3/4'		17'			
PROP. LINE TO BLDG.	3/4'		31'			

ENTERS: 804

BRANCHED INTO:

TAP SIZE: 1/2"

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION East side of 804


PRESSURE TEST: @ 100 psi For 4 Hrs. By DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION West side of Highland ST

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 020034

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY