

LOCATION 902 W. Airline Ave. CITY Easton Va

BETWEEN Weldon STREET & King STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>34'</u>	<u>8-8-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>14'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>20'</u>			

ENTERS: 906 W. Airline Ave. BRANCHED INTO: 902' W. Airline Ave.

TAP SIZE: 3/4 Straight PRESSURE 60 PSI INCHES W.C. LOCATION 235' E of C of N. Weldon
Plastic Tee


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AL

MAIN SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 11-13-91

DEPTH: 3 FT. 0 IN. LOCATION 63' N of C of W. Airline Ave. Renewed

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 429895

REMARKS: Split Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY