

LOCATION 2019 Audrey Dr. CITY Castroville  
BETWEEN Pamela STREET & Helen STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>Tied over 103' of EX 3/4 Plastic</u>		
MAIN TO PROP. LINE				<u>+ to New 2" Plastic Main</u>		
PROP. LINE TO BLDG.				<u>10-21-97</u>		

ENTERS: 2019 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY LB  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
Tested 5' New 3/4 Plastic with EX 103' 3/4 Plastic  
100 Psi 1/4 hr. 10-21-97



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY