


LOCATION 3109 Audrey DrCITY GASTON: ABETWEEN Impressal DrSTREET & Ridgeway

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	61	3-3-94		
MAIN TO PROP. LINE	3/4	P	5'			
PROP. LINE TO BLDG.	3/4	P	56'			

ENTERS: 3109 Audrey DrBRANCHED INTO: -TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 204' E of RidgewayPRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. DwyerMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 29' S of Audrey Dr"A" P/S READING P TOTAL ANODES 1\* 17\* \_\_\_\_\_ L.R. # 057822

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY