

LOCATION 1249 Audubon Dr. CITY GASTONIA

BETWEEN FALCON CT STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>146'</u>	<u>5-10-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>96'</u>			

ENTERS 1249 BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 339' SW. of center of Falcon Cr


PRESSURE TEST 100 PSI FOR 1/4 HRS BY S.H.

MAIN SIZE 2" C I RARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 23' NW of center of Audubon Dr

"A" P/S READING 2 TOTAL ANODES 1# 0 17# 0 I.R. # 358811

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	