

LOCATION 1248 Audubon Dr. CITY Gastonia
BETWEEN Falcon Ct STREET & Pheasant Cir. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	94'	1-18-02		
MAIN TO PROP LINE	5/8"	P	4'	"		
PROP LINE TO BLDG	5/8"	P	90'	"		

ENTERS 1248 BRANCHED INTO Ø

TAP SIZE 3/4" PRESSURE 100 PSI INCHES W C LOCATION 250' West of

Center of Falcon Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Wootley

MAIN-SIZE 2" C I Ø BARE STEEL Ø COATED STEEL Ø PLASTIC ✓ YEAR INSTALLED 1991

DEPTH 3' FT 0" IN LOCATION 23' North of center of Audubon Dr.

"A" P/S READING 11.1A TOTAL ANODES 1# Ø 17# Ø LR # 0007700

REMARKS New plastic service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>11.1A</u>

