

LOCATION 3617 Augusta CT. CITY GASTONIA

BETWEEN Cloister DR. STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>128'</u>	<u>2-15-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>83'</u>			

ENTERS: 3617 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 298' N. of center of Cloister DR


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1989

DEPTH 3 FT 0 IN. LOCATION 19' W. of center of Augusta CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 106514

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	