

LOCATION 3633 Augusta Ct. CITY  Gastonia  
BETWEEN Carroustic Ct. STREET & Cloister Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>102'</u>	<u>4-17-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>	<u>"</u>		
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>	<u>"</u>		

ENTERS 3633 BRANCHED INTO ⊖  
TAP SIZE 1/2" PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W/C LOCATION 619' North


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody  
of center of Cloister Dr.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1989

DEPTH 3' FT 0" IN LOCATION 18' West of center of Augusta Ct.

"A" P/S READING 11/17 TOTAL ANODES 1# ⊖ 17# ⊖ LR # 00287480

REMARKS New 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>