

LOCATION

1628 Auten Rd.

CITY

GASTONIA

BETWEEN

Brookneal Dr.

STREET &

Pine Ridge

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	100'	6-12-96		
MAIN TO PROP. LINE	3/4	Plastic	10'			
PROP. LINE TO BLDG.	3/4	Plastic	90'			

ENTERS:

1628

BRANCHED INTO: 0

TAP SIZE:

3/8"

PRESSURE

60

PSI

INCHES W.C.

LOCATION

130' S of C of Brookneal Dr.

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

RL

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

✓

PLASTIC

YEAR INSTALLED

1959

DEPTH:

3

FT.

6

IN.

LOCATION

14' E of C of Auten Rd.

"A" P/S READING

.90


TOTAL ANODES 1#

17#

L.R. #

311707

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY