

LOCATION 1814 Auten Rd. CITY GARTONIA

BETWEEN Fairlane Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>1/2"</u>	<u>Plastic</u>	<u>88'</u>	<u>9-18-01</u>		
MAIN TO PROP LINE	<u>1/2"</u>	<u>Plastic</u>	<u>16'</u>			
PROP LINE TO BLDG	<u>1/2"</u>	<u>Plastic</u>	<u>72'</u>			

ENTERS 1814 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 35' N of Caf Fairlane Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1959

DEPTH 3 FT 6 IN LOCATION 14' E of Caf Auten Rd.

"A" P/S READING 1.3 TOTAL ANODES 1#        17#        LR #       

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.25
P/S Pipeline Lead - White Existing Main	E	Galvanized