

LOCATION 2411 Autumn Chase CITY Constitution  
BETWEEN Old Mill Rd STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>92'</u>	<u>Relocated</u>	<u>12-5-78</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2411 BRANCHED INTO: 0

TAP SIZE: 3/4 Ser. PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ED

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED \_\_\_\_\_

DEPTH: 1 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY