

LOCATION 713 N. Adon St. CITY GASTONIA
BETWEEN Davidson STREET & Harrison STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | <u>102'</u> | <u>6-19-96</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>PLASTIC</u> | | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | | | | |

ENTERS: 713 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 64' S of C of Davidson Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1953
DEPTH: 3 FT. 6 IN. LOCATION 8' W of C of Adon St.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 325086

REMARKS:



| Test Station | | |
|---|----------|----------------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser PLASTIC</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY