

LOCATION 422 S. AVALON CITY GASTONIA

BETWEEN 4th STREET & MAPIO STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>95'</u>	<u>101399</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>65'</u>			

ENTERS: 422 BRANCHED INTO 0

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST: 100 PSI FOR 44 HRS. BY CP

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1995

DEPTH. 3 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #       

REMARKS:

Test Station		
Reading & Location	Lead	Notes
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

