

LOCATION 428 & 426 S. Arden CITY Canton
BETWEEN Maple STREET & 4th STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|------------|----------------|------------------------------|-----------------------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>41'</u> | | <u>Tied over</u> | <u>82' of Ext 3/4</u> |
| MAIN TO PROP. LINE | | | | <u>10-7-93</u> | <u>C/W Service to</u> | <u>#428 S. Arden</u> |
| PROP. LINE TO BLDG. | | | | | <u>to Ext 2" Plastic man</u> | |

ENTERS: 428 BRANCHED INTO: 426
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 14' W of Cat Arden
72' W of Cat 4th

PRESSURE TEST: @ 100 psi For 44 Hrs. By EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS: Tracer wire tied off at man



| Test Station | | |
|--|--------------------------|------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> <u>Riser</u> | <u>1.3</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY