

LOCATION 2304 Ogden Dr. CITY Easton
BETWEEN Ogden Dr. STREET & Black Springs STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85</u>	<u>7-26-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>33</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>52</u>			

ENTERS: 2304 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION E side of house


PRESSURE TEST: @ 100 psi For 7/4 Hrs. By Bonett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC - YEAR INSTALLED 1990

DEPTH: 2 Ft. 6 in. LOCATION 13' SAC pit

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # 00314090

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY