

LOCATION 1901 Ballard DR CITY Gastonia

BETWEEN Yellowstone CT STREET & N. New Hope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	113'	10-27-97		
MAIN TO PROP. LINE	3/4"	P	36'			
PROP. LINE TO BLDG.	3/4"	P	77'			

ENTERS: 1901 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 64' E. of center of

Yellowstone CT.


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Hurreford

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1947

DEPTH: 2 FT. 0 IN. LOCATION 14' S. of center of Ballard St.

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 738340

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY