

LOCATION 3513 Barrington Dr CITY Canton

BETWEEN Kendrick Rd. STREET & Cut-de-Sac STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|--------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG | <u>3/4"</u> | <u>P</u> | <u>90'</u> | <u>9-25-00</u> | | |
| MAIN TO PROP LINE | <u>3/4"</u> | <u>P</u> | <u>15'</u> | | | |
| PROP LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>75'</u> | | | |

ENTERS. 3573 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 43' N. of center of Kendrick Rd.


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.G.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1981

DEPTH 2 FT 0 IN LOCATION 12' W. of center of Barrington Dr

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 LR # 904530

REMARKS



| Test Station | | |
|---|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |